



NATIONAL
ENVIRONMENTAL
TESTING, INC.

APR 13 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

04/06/1998

NET Job Number: 98.02178
Page 1 of 3

Enclosed are the Analytical Results for the following samples submitted to NET, Inc. Indianapolis Division for analysis:

Project Description: TWICE WEEKLY WASTEWATER

Sample Number	Sample Description	Date Taken	Date Received
203186	OUTFALL 001	03/31/1998	03/31/1998

National Environmental Testing, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

Reproduction of this analytical report is permitted only in its entirety.

Theresa L. Shengold
Project Representative

MIL0003267



NATIONAL
ENVIRONMENTAL
TESTING, INC.

APR 13 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

04/06/1998

Sample No.: 203186
Job No.: 98.02178
P.O. NO.:

Page 2 of 3


Sample Description: OUTFALL 001
Job Description: TWICE WEEKLY WASTEWATER

Date Taken: 03/31/1998

Date Received: 03/31/1998

<u>Parameter</u>	<u>Result</u>	<u>Flag</u>	<u>Units</u>	<u>Analyst/ Date of Analysis</u>	<u>Method Number</u>	<u>Reporting Limit</u>
Iron, ICP	0.30		mg/L	tjg / 04/03/1998	E-200.7	<0.10
Lead, ICP	<0.080		mg/L	tjg / 04/03/1998	E-200.7	<0.080
Silver, ICP	<0.010		mg/L	tjg / 04/03/1998	E-200.7	<0.010
Zinc, ICP	1.3		mg/L	tjg / 04/03/1998	E-200.7	<0.020

MIL0003268



NATIONAL
ENVIRONMENTAL
TESTING, INC.

APR 13 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

FIELD REPORT

JOB #: 98.02178
CLIENT: MILBANK MFG.
PROJECT: TWICE WEEKLY WASTEWATER
DATE: 3/31/98
SAMPLER(S): MTM

An ISCO model 2910 auto sampler was used in the composite mode of operation. The sampler was equipped with a plastic composite jug, tygon suction line, battery, ice, and strainer.

All reusable equipment is decontaminated withalconox, tap water, 5% nitric acid, and deionized water. New tygon suction tubing was used for the sampler. A stainless steel strainer was also used for the sampling event.

The sampler was set to take a sample every 30 minutes for 24 hours.

Monitoring start 9:00 on 3/30/98
Monitoring end 9:00 on 3/31/98

The composite sample was cloudy, light brown color.

Notes: Samples were preserved, in the field, in the appropriate containers with any required preservative.

MIL0003269



COMPANY MILBANK MFG.

ADDRESS 1400 E. HAVENS ST.

PHONE (765) 452-5694

FAX

PROJECT NAME/LOCATION TWICE WEEKLY WASTEWATER

PROJECT NUMBER

PROJECT MANAGER

APR 13 1968

REPORT TO: RICHARD YLERT

INVOICE TO: _____

P.O. NO. _____

NET QUOTE NO. _____

SAMPLED BY

Michael Meyer
(PRINT NAME)

(PRINT NAME)

SIGNATURE

SIGNATURE

ANALYSES

To assist us in selecting the proper method

Is this work being conducted for regulatory compliance monitoring?

Yes _____ No _____

Is this work being conducted for regulatory enforcement action?

Yes _____ No _____

Which regulations apply: RCRA _____ NPDES Wastewater _____
UST _____ Drinking Water _____
Other _____ None _____

COMMENTS

[illegible]

CONDITION OF SAMPLE: BOTTLES INTACT? YES / NO
FIELD FILTERED? YES / NO

COC SEALS PRESENT AND INTACT? YES/NO
VOLATILES FREE OF HEADSPACE? YES/NO

TEMPERATURE UPON RECEIPT: 2.0°C
Bottles supplied by NET? YES ☒ NO ☐

SAMPLE REMAINDER DISPOSAL: RETURN SAMPLE REMAINDER TO CLIENT VIA _____
I REQUEST NET TO DISPOSE OF ALL SAMPLE REMAINDERS

DATE _____

RELINQUISHED BY:

DATE _____

TIME

RECEIVED BY:

REINOLISHED BY:

DATE _____

TIME

RECEIVED FOR NET BY:

Michael Hayes
METHOD OF SHIPMENT

3/31/98 16:15

REMARKS:

RECEIVED FOR NET BY: *3/31/98*
R. Barnett *1618*